

UWSP Health Enhancement Center

Area Description	Solution	Qty
V002 Ent.	2 F32T8 LW PS R	4
Janitor Rm	2 F32T8 LW PS	1
64	2VT8R 232 BPNP	2
64 A	2VT8R 232 BPNP	2
64 B	2VT8R 232 BPNP	2
60 Pool	No Change	9
60 Pool	No Change	32
60 Pool	No Change	4
60 Pool	No Change	0
60 Pool Rear Ent	19w PAR38 LED Kit	2
60 Pool	No Change	0
68	2 F32T8 HL PS K T	24
68	2 F32T8 PS K	4
68 A	2 F32T8 LW PS	2
60 A	No Change	6
60 B	2 F32T8 LW PS	4
60 Pool	No Change	4
60 C	No Change	0
60 Ent	7w LED kit	4
80 Stairs	2 F32T8 LW PS	1
80	2 F32T8 LW PS	4
81	2 F32T8 LW PS T	6
82	17w PAR38 LED	4
83	4 F32T8 LW PS	6
65	4 F32T8 LW PS	4
Hallways	2 F32T8 LW PS R	24
Hallways	7w LED kit	9
W3 Womens RR	No Change	6
W3 Womens RR	(2) F25T8 Re-lamp	6
W3 Womens RR	1 F32T8 PS RK T	8
W3 Womens RR	1 F32T8 Ps RK	1
Display Case	(2) F17T8 Relamp	6
66	2 F32T8 LW PS	1
67 Womens Locker	2 F32T8 LW PS	18
67 Womens Locker	4 F32T8 LW PS	1
67 Womens Locker	No Change	3
67 E RR	2 F32T8 LW PS T	4
Hall	1 F32T8 PS RK	12

Area Description	Solution	Qty
Ent	19w PAR38 LED Kit	1
Mens Locker	2 F32T8 LW PS	17
Mens Locker	4 F32T8 LW PS	1
Mens Locker RR	2 F32T8 LW PS T	4
Mens Locker RR	2 F32T8 LW PS T	4
M3 Men RR	No Change	6
M3 Men RR	1 F32T8 PS RK T	8
M3 Men RR	1 F32T8 PS RK	1
73 Janitor Closet	2 F32T8 LW PS	1
Ent	7w LED kit	9
Hall	4 F32T8 LW PS	2
Loading Dock	No Change	6
Hall	1 F32T8 PS RK	28
Gym	No Change	0
Hall	1 F32T8 LW PS	1
Equipment	No Change	0
24	2 F32T8 LW PS	2
25 Womens Rm	2 F32T8 LW PS	10
26 Womens Locker	2 F32T8 LW PS	5
26 Womens Locker	1 F32T8 LW PS	19
26 Womens Shower	No Change	8
19 EQ	2 F32T8 LW PS	2
26 D	No Change	0
27	13w PAR30 LED	21
27	2VT8R 217 BPNP	2
28	2 F32T8 LW PS	2
29	2 F32T8 LW PS	1
31	2 F32T8 LW PS	1
32 Mens Locker	2 F32T8 LW PS	5
32 Mens Locker	1 F32T8 LW PS	28
32 Mens RR	No Change	0
32 A	No Change	0
32 E	2 F32T8 LW PS	9
32 D	1 F32T8 LW PS	9
32 C	1 F32T8 LW PS	7
33	2 F32T8 PS R	12
Womens RR	2 F32T8 LW PS	5
Mens RR	2 F32T8 LW PS	5

Area Description	Solution	Qty
21 Electrical	18w CFL	1
Lobby	4 F32T8 LW PS	2
Lobby	6 F32T8 LW PS	9
Lobby	No Change	0
Display Cases	7w LED MR16	10
Lobby Ent	1 F32T8 PS RK	12
Lobby Ent	Photoeye	1
Ticket Office	No Change	0
Stair Landings	2 F32T8 LW PS	2
Storage Rm	No Change-Low Hours	3
36 Raquetball Court	No Change	12
36 Raquetball Court	1 F32T8 PS RK	4
Hall Display Case	1 F32T8 LW PS	1
Hall	1 F32T8 PS RK	36
38	WL 43296 PS	21
38	WL 43296 PS	1
38	2 F32T8 PS R	20
38	1 F32T8 PS RK	4
38	LED Exit	1
42	4 F32T8 LW PS	12
Hall	No Change	1
Ent	2 F32T8 LW PS	1
Janitor Closet	2 F32T8 LW PS	1
40	2 F32T8 PS R	33
40	LED Exit	1
40 D	2 F32T8 LW PS	2
40 E	2 F32T8 PS R	2
40 C	2 F32T8 PS R	2
40 B	1 F32T8 PS RK T	6
40 A	2VT8R 232 BPNP	2
Hall (Tunnel)	WL 13248 PS	3
Football Mens Locker	No Change	0
Mens Team Room	2 F32T8 LW PS	36
Mens Offices	2 F32T8 PS RKw	2
Mens Offices	2 F32T8 LW PS	4
Mens Shower	1 F32T8 LW PS	2
Men RR	2 F32T8 LW PS	1
Women RR	2 F32T8 LW PS	1

Area Description	Solution	Qty
45 Women RR	2 F32T8 LW PS	7
46 Men RR	2 F32T8 LW PS	7
Locker Area Hall	2 F32T8 LW PS	18
05 -- 04	2 F32T8 LW PS	13
3	2 F32T8 LW PS T	10
05 Storage	2 F32T8 LW PS	4
2	No Change	0
7	-	0
Door #2	2 F32T8 LW PS	1
Room 1	No Change	1
Womens Locker	2 F32T8 LW PS	18
Womens Locker	No Change	0
Womens Hall St.	2 F32T8 LW PS	4
Fieldhouse	(6) 49W RELAMP	120
Fieldhouse	(4) 49W RELAMP	12
72	2VT8R 232 BPLP	2
71	2 F32T8 LW PS	8
Berg Gym Control Rm	2 F32T8 LW PS R	2
2nd Floor	-	0
Hallways	1 F32T8 PS RK T	12
Hallways	1 F32T8 PS RK	20
ROTC Office Area	(2) F32T8 Relamp	47
ROTC Office Area	No Change	0
ROTC Mech	No Change-Low Hours	2
Stairs	2 F32T8 LW PS	6
Janitor Closet	No Change-Low Hours	1
154	WL 23296 PS	18
154 Dance Studio	No Change-Low Hours	20
154 B	2 F32T8 LW PS	2
110 Bennett Gym	(8) 49W T5 RELAMP	28
110 Bennett Gym	(16) 49W T5 RELAMP	22
110 Bennett Gym	(10) 49W T5 RELAMP	4
110 Bennett Gym	(2) 49W T5 RELAMP	3
110 Bennett Gym	(12) 49W T5 RELAMP	8
Bennett Gym Mezz	(4) 49w T5 RELAMP	17
110 Balcony	2 F32T8 LW PS R	8
146 B	1 F32T8 PS R	3
146 RR	1 F32T8 PS RK	1

Area Description	Solution	Qty
154 A	WL 23296 PS	4
148	2 F32T8 LW PS	5
147	2VT8R 232 BPLP	15
146 A	No Change	0
143	2VT8R 232 BPLP	2
142	2 F32T8 LW PS	1
146	2VT8R 232 BPLP	20
146	7w LED kit	17
146	9w LED	15
146 Hall	1 F32T8 PS RK	2
116	2VT8R 232 BPLP	10
116	13w PAR30 LED	10
116 A	2 F32T8 LW PS	4
Womens Faculty Locker	1 F32T8 PS RK	5
Womens Faculty Locker	No Change	0
Mens Faculty Locker	1 F32T8 PS RK	5
Mens Faculty Locker	No Change	1
120	No Change	0
140	2VT8R 232 BPLP	3
137	1 F32T8 PS RK T	4
138	1 F32T8 PS RK T	4
135	1 F32T8 PS RK T	4
136	1 F32T8 PS RK T	4
133	1 F32T8 PS RK T	4
134	1 F32T8 PS RK T	4
131	1 F32T8 PS RK T w/pris	4
132	1 F32T8 PS RK T	4
129	1 F32T8 PS RK T w/pris	4
130	1 F32T8 PS RK T	4
127	1 F32T8 PS RK T	4
128	1 F32T8 PS RK T	4
124	1 F32T8 PS RK T	8
125	1 F32T8 PS RK T	4
125	1 F32T8 PS RK	2
123	1 F32T8 PS RK T	4
123	1 F32T8 PS RK	2
122	1 F32T8 PS RK T	4
121	1 F32T8 PS RK	1

Area Description	Solution	Qty
Hallways	2 F32T8 LW PS R	8
118 Hall	1 F32T8 PS R	1
118	1 F32T8 PS R	4
118 C	2VT8R 232 BPLP	4
119	2VT8R 232 BPLP	15
118 A	2VT8R 232 BPLP	4
116 Hall	1 F32T8 PS RK	2
118 B	2VT8R 232 BPLP	4
M101 Men RR	1 F32T8 PS RK	4
Lounge	1 F32T8 PS R	4
117	2VT8R 232 BPLP	3
117 A	2VT8R 232 BPLP	2
117 B	2VT8R 232 BPLP	2
117 C	2VT8R 232 BPLP	2
112	No Change	2
115	2VT8R 232 BPLP	2
W101 Women RR	1 F32T8 PS RK	4
Hall	WL 13248 PS	7
110 F	No Change	0
110 E	No Change	0
Wrestling Rm	No Change	0
104 Office Area	2VT8R 232 BPLP	10
104 Office Area	13w PAR30 LED	2
113	2VT8R 232 BPLP	2
111	2VT8R 232 BPLP	2
109	2VT8R 232 BPLP	2
107	2VT8R 232 BPLP	2
105	2VT8R 232 BPLP	4
102	No Change	0
100 Gym	(4) 49w T5 RELAMP	12
100 Gym	(12) 49W T5 RELAMP	30
100 A	27w CFL	1
100 Lobby Ent	WL 13248 PS	10
101	2VT8R 232 BPLP	9
103	2VT8R 232 BPLP	4
103 A	27w CFL	1