

UWSP University Center

Area Description	Solution	Qty
University Center	-	0
Basement	-	0
70 Study Area	4 F32T8 LW PS	12
70 Study Area	7W LED KIT - D	6
70A Storage	No Change-Low Hours	0
70B Study Room	2VT8R 232 BPLP	6
70C Study Room	2VT8R 232 BPLP	6
70D Study Room	2VT8R 232 BPLP	4
70E Office	2VT8R 232 BPLP	2
70F Office	2VT8R 232 BPLP	2
70G Office	2VT8R 232 BPLP	2
70H Office	2VT8R 232 BPLP	2
70J Office	2VT8R 232 BPLP	4
70K Study Area	2VT8R 232 BPLP	6
70M Study Area	2VT8R 232 BPLP	6
70N Storage	No Change	0
68 Office	2VT8R 232 BPLP	3
65 Study Room	2VT8R 232 BPLP	6
64 Study Room	2VT8R 232 BPLP	6
Hallways	1 F32T8 PS R	21
63 Study Room	2VT8R 232 BPLP	3
66 Study Room	2VT8R 232 BPLP	6
C74 Hall	2 F32T8 LW PS	10
Elevator	(2) F25T8 Re-lamp	2
74 Storage	No Change-Low Hours	0
75 Mech	No Change-Low Hours	0
75A Mech	No Change-Low Hours	0
80/81 Elec Room	No Change-Low Hours	0
80/81 Elec Room	No Change-Low Hours	0
73 Elev Equip	No Change-Low Hours	0
76 Custodial	No Change-Low Hours	0
82 Mech Rm	No Change-Low Hours	0
82 Mech Rm	No Change-Low Hours	0
40B Pantry	1 F32T8 PS R	3
77 St	No Change-Low Hours	0
Washroom	No Change-Low Hours	0
60A Office	2VT8R 232 BPLP	4
62 Study Area	2VT8R 232 BPLP	4

Area Description	Solution	Qty
Men RR	1 F32T8 PS RK	2
Women RR	1 F32T8 PS RK	2
62A Vacant Office	2VT8R 232 BPLP	2
56 Mech	No Change-Low Hours	0
56 A/B St	No Change-Low Hours	0
Sub Basement Hall	1 F32T8 LW PS	10
Hall Display	1 F32T8 LW PS	1
61 Pantry	2VT8R 232 BPLP	3
60 Study Area	2VT8R 232 BPLP	10
54 Conf Room	2VT8R 232 BPLP	2
54 Conf Room	7w LED KIT - D	5
50 Lounge	7W LED MR16	10
50 Lounge	1 F32T8 PS R	12
50 Lounge	2 F32T8 LW PS	5
50 Lounge	2VT8R 232 BPLP	16
50 Lounge	NO CHANGE	0
50 Lounge	4 F32T8 LW PS	1
50J Office	2VT8R 232 BPLP	2
50H Office	2VT8R 232 BPLP	4
50G Office	2VT8R 232 BPLP	2
50F Office	2VT8R 232 BPLP	2
50E Office	2VT8R 232 BPLP	2
50D Office	2VT8R 232 BPLP	2
50C Office	2VT8R 232 BPLP	2
50C Office	7w LED KIT - D	4
50B Office	2VT8R 232 BPLP	6
51 Mech Rm	No Change-Low Hours	0
51 Tunnel	No Change	0
51A Mech	No Change-Low Hours	0
51B Elec	No Change	0
52 Office	2VT8R 232 BPLP	5
52A Office	2VT8R 232 BPLP	2
52B St	No Change-Low Hours	0
52C Office	2VT8R 232 BPLP	2
52D Office	2VT8R 232 BPLP	2
59 Mech	No Change-Low Hours	0
59 Mech	No Change-Low Hours	0
57 Mech	No Change-Low Hours	0

Area Description	Solution	Qty
57 Mech	No Change-Low Hours	0
B Stairs Landing	2 F32T8 LW PS	3
40 Lounge	7W PAR20 LED	21
40 Lounge	9w LED	6
40 Lounge	1 F32T8 PS R	5
40 Lounge	15W CFL	40
40 Lounge	2 F32T8 LW PS	17
40 Lounge Over Couch/ Pool tables	7W LED	21
41 Conf Room	2VT8R 232 BPLP	6
41 Conf Room	7W LED	6
Elev. Landing	7W LED KIT - D	1
1st Floor	-	0
C41 Elev Landing	7W LED KIT - P	1
Stairwell Shaft	(1) 49W RELAMP	8
Hallway	2 F32T8 LW PS	18
Hallway	14w PAR38 LED	12
Hallway	7w LED KIT - D	2
Vending Area	(1) 49W RELAMP	3
Study Area	(1) 49W RELAMP	35
RR Ent	7W LED KIT - P	2
Men RR	2 F32T8 LW PS	5
Women RR	2 F32T8 LW PS	5
Encore Lobby	7W LED KIT - P	5
110A Encore Ticket Office	7W LED KIT - P	6
Encore	2 F32T8 LW PS	16
Encore	15W CFL	9
112A St	No Change-Low Hours	0
The Theater	19w PAR38 LED kit	43
Control Room	No Change-Low Hours	0
Control Room	9w LED	1
Theater Ent/ Lobby	7w LED KIT - P	2
Theater Ent/ Lobby	2 F17T8 RELAMP	3
C101 Corridor	7w LED KIT - P	6
C101 Corridor	No Change	0
B110 Entrance	7w LED KIT - P	10
108 BANK	7w LED KIT - P	9
106 Café	7w LED KIT - P	14
106 Café	2 F32T8 LW PS	10

Area Description	Solution	Qty
106 Café Walk-in	(2) 49W RELAMP	1
104 Lounge	7w LED KIT - P	8
102 Information	7w LED KIT - P	25
102C Information	7w LED KIT - P	4
102B Information Office	7w LED KIT - P	6
102A Information Storage	7w LED KIT - P	2
V101 Entrance	7w LED KIT - P	5
Bookstore Ent/ Stair	7w LED KIT - S	3
Bookstore Display	7W LED MR16	4
Bookstore Elev. Landing	(1) 49W RELAMP	2
20 Bookstore	7w LED KIT - D	8
20 Bookstore	7w LED KIT - P	46
20 Bookstore	2VT8R 232 BPLP	118
20 Bookstore	(1) 49W RELAMP	17
20 Bookstore	13w PAR30 LED	24
20 Bookstore	7W LED MR16	40
20 Bookstore Display	1 F25T8 LW PS T	24
20 Bookstore Display	1 F32T8 LW PS T	26
21 Bookstore Office Area	2VT8R 232 BPNP	10
24 Office	2VT8R 232 BPLP	4
23A Fileroom	2VT8R 232 BPLP	1
22 Vacant Office	2VT8R 232 BPLP	2
22A Office	2VT8R 232 BPLP	1
21A Office	2VT8R 232 BPLP	2
Fitting Room	No Change	0
32 and 31 Storeroom	2 F32T8 LW PS R	61
32 and 31 Storeroom	2 F32T8 LW PS	2
Men RR	2 F32T8 LW PS R	1
Women RR	2 F32T8 LW PS R	1
Custodial	No Change-Low Hours	0
32B Elev Equip	No Change-Low Hours	0
32A Breakroom	2 F32T8 LW PS R	2
31C Office	2VT8R 232 BPLP	2
20B Office	2VT8R 232 BPLP	2
31A	No Change	0
31B	No Change	0
39 Janitor's Closet	No Change-Low Hours	0
34 Office	2VT8R 232 BPLP	2

Area Description	Solution	Qty
2nd Floor	-	0
221	No Change	0
222 St	No Change-Low Hours	0
222A Women RR	2 F32T8 LW PS	7
222A Women RR	No Change	0
222A Women Mother's Room	No Change	0
222B Men RR	2 F32T8 LW PS	7
222B Men RR	No Change	0
Halls/ Lobby	2 F32T8 LW PS	70
Halls/ Lobby	17w PAR38 LED	18
223 Conf	3 F32T8 LW PS	6
224 Mech	No Change-Low Hours	0
225 St	No Change-Low Hours	0
225 St	No Change-Low Hours	0
Back Area Hall	1 F32T8 LW PS R	22
245 Locker Area	1 F32T8 HL PS R	6
241 Office	2VT8R 232 BPLP	4
241A St	No Change	0
242 Pantry	1 F32T8 PS R	2
245 Men RR	1 F32T8 LW PS RK	2
245A Custodial	No Change-Low Hours	0
245 Women RR	1 F32T8 PS RK	2
242A Kitchen St	No Change-Low Hours	0
233 Kitchen	1 F32T8 HL PS R	8
231 Table St	No Change-Low Hours	0
232 Storage	No Change-Low Hours	0
Freight Elev	No Change	0
284 Loading Dock	4 F32T8 LW PS	3
284 Loading Dock	2 F32T8 LW PS	2
284 Area Hall	2 F32T8 LW PS	5
280 Pantry	2 F32T8 LW PS	12
280 Pantry Walk In	7w LED	2
275 Custodial	No Change-Low Hours	0
270 Kitchen	2 F32T8 LW PS R	38
271 Soda Syrup	2 F32T8 LW PS R	1
272 Office	2 F32T8 LW PS R	2
270 Walk Ins (3)	(2) 49W RELAMP	6
260 Serving Area	17W PAR38 LED Kit	35

Area Description	Solution	Qty
260 Serving Area	7w LED Kit - S	3
260 Serving Area	No Change	0
260 Serving Area	7w LED KIT - P	22
260 Beverage Reach In	3-door 5' LED	1
260 Hood	2 F32T8 LW PS	2
260 Lounge Area	7w LED KIT - X	6
250 Serving Area	7W LED MR16	22
250 Serving Area	7W LED KIT - D	70
260 Serving Area	7W LED KIT - D	18
250 Serving Area	17W PAR38 LED Kit	80
250 Serving Area	No Change	0
250B Pantry	2 F32T8 LW PS	2
250C Chem St	No Change-Low Hours	0
251A Mech	No Change-Low Hours	0
Hall C240	17W PAR38 LED Kit	7
Hall C240	7W LED KIT - S	3
240 Office	2VT8R 232 BPLP	4
240A Office	2VT8R 232 BPLP	2
240B Office	2VT8R 232 BPLP	2
Men Dressing Room	1 F32T8 LW PS RK	2
Men Dressing Room	2 F32T8 LW PS	1
Men Dressing Room	7w LED KIT - X	1
Men Vanity	No Change	0
Women Dressing Room	1 F32T8 LW PS RK	2
Women Dressing Room	2 F32T8 LW PS	1
Women Dressing Room	7w LED KIT - X	1
Women Vanity	No Change	0
238 Comm Room	2 F32T8 LW PS	4
RR	2 F32T8 LW PS	1
Laird Rm Entrys	7w LED KIT - X	8
Women RR	2 F32T8 LW PS	7
Women RR	7W LED KIT - X	1
Display Cases	7W LED MR16	4
Men RR	2 F32T8 LW PS	7
Men RR	7W LED KIT - X	1
236 Conf	2 F32T8 LW PS	6
Galleries	7W LED MR16	32
235A Workroom	2 F32T8 LW PS	2

Area Description	Solution	Qty
235A Workroom	1 F32T8 LW T	4
235A Workroom	2 F32T8 LW PS	6
235A Workroom	9W LED	12
230 Laird Rm	13w PAR30 LED	5
230 Laird Rm	(1) F32T8 RELAMP	52
230 Laird Rm	50w PAR56 LED Kit	126
212 Area Hall	No Change	0
212 Stairs	2 F32T8 LW PS	4
251 Mech	No Change-Low Hours	0
211 Conf	2VT8R 232 BPLP	6
Halls/ Lounge	7w LED KIT - P	21
210 Centertainment	RT8B 132 BPNP	12
210 Centertainment	17W PAR38 LED	1
210 Centertainment	7W LED KIT - P	4
208 Resource Center	RT8B 132 BPNP	8
208A Office	RT8B 132 BPNP	2
208B Study Room	RT8B 132 BPNP	6
206 Rec Office	RT8B 132 BPNP	10
206 Rec Office	7W LED KIT - P	4
206A Office	RT8B 132 BPNP	2
204 Haircraft	RT8B 132 BPNP	8
203 Computer Labs	RT8B 132 BPNP	13
203A Study	RT8B 132 BPNP	1
201 Computer Labs	RT8B 132 BPNP	2
201 Computer Labs	4 F32T8 LW PS	6
3rd Floor	-	0
Elev. Lounge	2 F32T8 LW PS	1
Lobby/ Hall	2 F32T8 LW PS	18
Admin Area	2VT8R 232 BPLP	45
Admin Area	7W LED KIT - D	4
Admin Kitchenette	2VT8R 232 BPLP	2
344A Office	2VT8R 232 BPLP	2
344B Office	2VT8R 232 BPLP	2
344C Office	2VT8R 232 BPLP	2
344D Office	2VT8R 232 BPLP	2
344E Office	2VT8R 232 BPLP	2
344F Office	2VT8R 232 BPLP	2
340D Conf	2VT8R 232 BPLP	2

Area Description	Solution	Qty
344F Office	2VT8R 232 BPLP	2
340D Conf	2VT8R 232 BPLP	2
340C Workroom	2VT8R 232 BPLP	4
340E Storage	No Change-Low Hours	0
340F Office	2VT8R 232 BPLP	3
340G Office	2VT8R 232 BPLP	2
340H Office	2VT8R 232 BPLP	2
340J Office	2VT8R 232 BPLP	2
340K Office	2VT8R 232 BPLP	2
340N Equip St	No Change-Low Hours	0
340M Elev Equip	No Change	0
351 Mech	No Change	0
Hallway	2 F32T8 LW PS	18
Meeting Room Halls	2 F32T8 LW PS	13
370 Legacy Room- Conf	2 F32T8 LW PS	36
370 Legacy Room	17W PAR38 LED	4
370 Legacy Room	(2) F17T8 RELAMP	6
370B Storage	No Change	0
370A Kitchen Storage	No Change-Low Hours	0
360A Kitchen St	No Change-Low Hours	0
360 Kitchen St	No Change-Low Hours	0
360C Mech	No Change-Low Hours	0
379 St	No Change-Low Hours	0
378 Conf	2VT8R 232 BPLP	12
378 Conf	No Change	0
376 Conf	2VT8R 232 BPLP	6
374 Conf	2VT8R 232 BPLP	12
373 Office	1 F32T8 PS R	2
372 Custodial	No Change-Low Hours	0
372 St	No Change-Low Hours	0
Women RR	2 F32T8 LW PS	6
Men RR	2 F32T8 LW PS	6
363 Office	2 F32T8 LW PS	6
350 Alumni Rm	19w PAR38 LED KIT	36
350 Alumni Rm	7w LED KIT - P	27
350 Alumni Rm	No Change	0
361 Table St.	No Change-Low Hours	0
362 Mech	No Change-Low Hours	0

Area Description	Solution	Qty
Emergency Stairwells	No Change	0